

**Attachment to “Affidavit And Certification Of The Total Mwh Quantity Generated By The Hope Creek,
Salem 1 And Salem 2 Nuclear Plants” of Eric Carr, President and Chief Nuclear Officer Power
of PSEG Nuclear LLC, dated June 29, 2020, describing loss events for Salem 2 Nuclear Unit**

Pursuant to the May 20, 2020 BPU Order, all loss events have been reviewed and meet the following allowable exceptions:

The selected nuclear power plant should operate at its maximum output, with the exception of;

- (1) reduced output or outages associated with equipment maintenance and/or repair that a prudent owner or operator of a nuclear power plant would undertake,
- (2) NRC license limitations, fuel limitations (for example, rod pattern adjustments, end of operating cycle fuel management, and coast downs),
- (3) any PJM imposed constraints,
- (4) and other events beyond its reasonable control that are classified as Force Majeure events.

| Salem Unit 2 Total Losses: 1,282,765 MWhr | | | | | | | |
|--|--------------|--------------------------|---------------------|---------------------|---|---|---------------------------|
| START | END | DERATED HOURS | MWe Loss | MWh Loss | REASON | Allowed Exception Category | NERC/GADS Code |
| 6/1/19 0:00 | 7/1/19 0:00 | 720.0 | 0 | 136 | Blowdown losses for the month due to condenser tube leaks. | 1 | 3110 |
| 6/15/19 9:51 | 6/16/19 4:32 | 18.7 | 22 | 411 | 21HD9 Htr Drain Pump Condenser Recirc Valve Failed Open (Heater Drains) | 1 | 3504 |
| 7/14/19 0:48 | 7/15/19 0:41 | 23.9 | 25 | 597 | Stopped 21B Circulator Pump for Condenser tube plugging. | 1 | 3110 |
| 7/15/19 15:50 | 7/16/19 1:19 | 9.5 | 27 | 256 | Stopped 23A Circulator Pump for pump repack and waterbox cleaning. | 1 | 3210 |
| 8/2/19 7:05 | 8/2/19 8:00 | 0.9 | 66 | 61 | Lowering turbine load for turbine valve testing. | 1 | 3210 |
| 8/2/19 8:00 | 8/2/19 11:01 | 3.0 | 137 | 413 | Turbine valve testing. | 1 | 3210 |
| 8/2/19 11:01 | 8/2/19 12:50 | 1.8 | 51 | 93 | Power ascension following turbine valve testing. | 1 | 3210 |

| Salem Unit 2 Total Losses: 1,282,765 MWhr | | | | | | | |
|---|----------------|---------------|----------|----------|--|----------------------------|----------------|
| START | END | DERATED HOURS | MWe Loss | MWh Loss | REASON | Allowed Exception Category | NERC/GADS Code |
| 8/11/19 7:38 | 8/11/19 8:13 | 0.6 | 83 | 48 | Main Bus Duct cooling repairs | 1 | 4805 |
| 8/11/19 8:13 | 8/14/19 12:21 | 76.1 | 1216 | 92578 | Manual RX Trip due Feed Reg valve 23BF19 instability. | 1 | 3430 |
| 8/14/19 12:21 | 8/15/19 9:57 | 21.6 | 426 | 9202 | Power ascension to 100% following RX trip. | 1 | 3430 |
| 9/16/19 0:06 | 9/28/19 4:07 | 292.0 | 16 | 4672 | Stopped the 21A Circulator Pump for planned maintenance | 1 | 3110 |
| 10/5/19 23:55 | 10/6/19 2:59 | 3.1 | 9 | 28 | 23HD15 Htr Drn Pump Discharge Level Control Valve Not Controlling Properly | 1 | 3501 |
| 10/6/19 17:35 | 10/8/19 16:09 | 46.6 | 19 | 885 | Repair 21A Condenser Tube Leak | 1 | 3110 |
| 10/19/19 2:46 | 10/19/19 20:33 | 17.8 | 14 | 249 | 23HD15 Htr Drn Pump Discharge Level Control Valve Not Controlling Properly | 1 | 3501 |
| 10/25/19 10:02 | 10/25/19 14:02 | 4.0 | 1 | 4 | 21C Feedwater Heater troubleshooting | 1 | 3501 |
| 11/1/19 2:30 | 11/1/19 14:41 | 12.2 | 5 | 61 | 23HD15 Htr Drn Pump Discharge Level Control Valve Not Controlling Properly | 1 | 3501 |
| 11/8/19 8:05 | 11/8/19 21:35 | 13.5 | 4 | 54 | 23HD15 Htr Drn Pump Discharge Level Control Valve Not Controlling Properly | 1 | 3501 |
| 11/9/19 10:24 | 11/9/19 12:51 | 2.4 | 5 | 12 | 23HD15 Htr Drn Pump Discharge Level Control Valve Not Controlling Properly | 1 | 3501 |
| 11/11/19 3:30 | 11/15/19 15:53 | 108.4 | 7 | 759 | Stopped 22B Circulator Pump for 22CW109 maintenance. | 1 | 3210 |
| 11/15/19 10:24 | 11/19/19 18:55 | 104.5 | 6 | 627 | Stopped 21A Circulator Pump due to condenser tube leak. | 1 | 3110 |

| Salem Unit 2 Total Losses: 1,282,765 MWhr | | | | | | | |
|---|----------------|---------------|----------|----------|--|----------------------------|----------------|
| START | END | DERATED HOURS | MWe Loss | MWh Loss | REASON | Allowed Exception Category | NERC/GADS Code |
| 11/23/19 3:08 | 11/24/19 0:32 | 21.4 | 4 | 86 | Stopped 22A Circulator Pump for planned maintenance. | 1 | 3210 |
| 11/12/19 10:45 | 11/16/19 2:42 | 88.0 | 2 | 167 | SG Blowdown Losses for month | 1 | 3110 |
| 12/3/19 0:19 | 12/4/19 21:10 | 45.9 | 8 | 367 | 21B Circulating Water Pump was removed from service at 0019 for scheduled maintenance. | 1 | 3210 |
| 12/10/19 13:37 | 12/15/19 14:47 | 121.2 | 3 | 363 | Stopped 22B Circulator Pump due to condenser tube leak. | 1 | 3110 |
| 12/16/19 0:30 | 12/22/19 4:13 | 147.7 | 6 | 886 | 23B Circulating Water Pump was removed from service for scheduled maintenance. | 1 | 3210 |
| 12/26/19 11:00 | 12/26/19 17:39 | 6.7 | 3 | 20 | 23B Circulating Water Pump was removed from service for waterbox cleaning. | 1 | 3210 |
| 12/27/19 11:00 | 12/27/19 18:29 | 7.5 | 3 | 22 | 22A Circulating Water Pump was removed from service for waterbox cleaning. | 1 | 3210 |
| 12/27/19 21:31 | 12/28/19 3:24 | 5.9 | 3 | 18 | 23A Circulating Water Pump was removed from service for waterbox cleaning. | 1 | 3210 |
| 12/28/19 8:00 | 12/28/19 13:53 | 5.9 | 3 | 18 | 21B Circulating Water Pump was removed from service for waterbox cleaning. | 1 | 3210 |
| 1/1/20 2:00 | 1/1/20 2:55 | 0.9 | 3 | 3 | Stopped 23B Circulator Pump to support travelling screen D/P work. | 1 | 3260 |
| 1/5/20 3:06 | 1/5/20 4:53 | 1.8 | 5 | 9 | Lowered Turbine Load to Replace Heater Drain Tank Level Transformer | 1 | 3502 |
| 1/5/20 23:30 | 1/11/20 5:30 | 126.0 | 2 | 252 | Stopped 23A Circulator Pump for scheduled traveling screen maintenance. | 1 | 3260 |

| Salem Unit 2 Total Losses: 1,282,765 MWhr | | | | | | | |
|---|---------------|---------------|----------|----------|---|----------------------------|----------------|
| START | END | DERATED HOURS | MWe Loss | MWh Loss | REASON | Allowed Exception Category | NERC/GADS Code |
| 1/7/20 14:36 | 1/7/20 15:29 | 0.9 | 5 | 4 | Lowered Turbine Load to Replace Heater Drain Tank Level Transformer | 1 | 3502 |
| 1/12/20 20:40 | 1/16/20 16:47 | 92.1 | 3 | 276 | Stopped 22A Circulator Pump for scheduled maintenance | 1 | 3210 |
| 1/12/20 21:00 | 1/13/20 19:10 | 22.2 | 28 | 621 | Moderator Temperature Coefficient Testing | 1 | 2040 |
| 1/19/20 23:08 | 1/27/20 22:38 | 191.5 | 2 | 383 | Stopped 22B Circulator Pump for scheduled maintenance | 1 | 3210 |
| 1/19/20 1:11 | 1/30/20 1:14 | 264.0 | 2 | 528 | Stopped 21B Circulator Pump for scheduled maintenance | 1 | 3210 |
| 1/30/20 2:59 | 2/1/20 0:00 | 45.0 | 2 | 90 | Stopped 21A Circulator Pump for scheduled maintenance | 1 | 3210 |
| 2/1/20 0:00 | 2/2/20 4:39 | 28.6 | 2 | 57 | Stopped 21A Circulator Pump for scheduled maintenance | 1 | 3210 |
| 2/8/20 19:30 | 2/9/20 3:29 | 8.0 | 3 | 24 | Stopped 22B Circulator Pump for waterbox cleaning | 1 | 3273 |
| 2/20/20 7:45 | 2/20/20 18:54 | 11.2 | 3 | 33 | Stopped 22B Circulator Pump for trveling screen maintenance. | 1 | 3260 |
| 2/24/20 21:36 | 2/27/20 21:37 | 72.0 | 5 | 360 | Stopped 21A Circulator Pump for a condenser tube leak. | 1 | 3110 |
| 3/8/20 22:30 | 3/9/20 4:43 | 6.2 | 3 | 19 | Stopped 22B Circulator Pump for waterbox cleaning | 1 | 3273 |
| 3/14/20 12:07 | 3/15/20 1:05 | 13.0 | 4 | 52 | Stopped 22A Circulator Pump for pump packing work | 1 | 3210 |

| Salem Unit 2 Total Losses: 1,282,765 MWhr | | | | | | | |
|---|---------------|---------------|----------|----------|--|----------------------------|----------------|
| START | END | DERATED HOURS | MWe Loss | MWh Loss | REASON | Allowed Exception Category | NERC/GADS Code |
| 3/18/20 4:04 | 3/19/20 1:44 | 21.7 | 5 | 108 | Stopped 22A Circulator Pump for pump alignment work | 1 | 3210 |
| 3/21/20 21:24 | 3/23/20 3:08 | 29.7 | 5 | 149 | Stopped 22A Circulator Pump for pump packing work | 1 | 3210 |
| 3/26/20 23:39 | 3/27/20 9:30 | 9.8 | 5 | 49 | Stopped 22B Circulator Pump for waterbox cleaning | 1 | 3273 |
| 3/18/20 22:00 | 4/1/20 0:00 | 314.0 | 23 | 7222 | Began Coastdown into 2R24 IAW S2.OP-IO.ZZ-0004, Attachment 9 | 2 | 9110 |
| 4/4/20 21:45 | 4/11/20 0:01 | 146.3 | 5 | 731 | Stopped the 22B Circulator Pump for planned maintenance. | 1 | 3210 |
| 4/10/20 19:40 | 4/11/20 0:01 | 4.4 | 582 | 2532 | Shutdown for Refueling Outage 2R24 | 1 | 2070 |
| 4/1/20 0:00 | 4/10/20 19:40 | 235.7 | 87 | 20401 | Refueling Outage 2R24 Coastdown | 2 | 9110 |
| 4/11/20 0:01 | 5/1/20 0:00 | 480.0 | 1216 | 583660 | Refueling Outage 2R24 | 1 | 2070 |
| 5/1/20 0:00 | 5/9/20 0:01 | 192.0 | 1216 | 233492 | Refueling Outage 2R24 | 1 | 2070 |
| 5/9/20 0:01 | 5/12/20 13:39 | 85.6 | 1216 | 104130 | Refueling Outage Extension 2R24 | 1 | 2070 |
| 5/12/20 13:39 | 5/13/20 6:03 | 16.4 | 839 | 13760 | Startup From 2R24 (Stopped for stator water pump seal leak) | 1 | 2070 |
| 5/13/20 6:03 | 5/13/20 18:07 | 12.1 | 768 | 9267 | Stator water pump seal leak | 1 | 4650 |
| 5/13/20 18:07 | 5/14/20 15:18 | 21.2 | 431 | 9130 | Startup From 2R24 (Stopped for 24BF19 Problem) | 1 | 2070 |
| 5/14/20 15:18 | 5/14/20 17:13 | 1.9 | 740 | 1418 | Power reduction (from 73%) to repair 24BF19 | 1 | 3430 |
| 5/14/20 17:13 | 5/18/20 5:52 | 84.6 | 1216 | 102934 | Forced Outage to repair 24BF19 | 1 | 3430 |

| Salem Unit 2 Total Losses: 1,282,765 MWhr | | | | | | | |
|---|---------------|---------------|----------|----------|---|----------------------------|----------------|
| START | END | DERATED HOURS | MWe Loss | MWh Loss | REASON | Allowed Exception Category | NERC/GADS Code |
| 5/18/20 5:52 | 5/18/20 15:31 | 9.7 | 828 | 7990 | S/U from Forced Outage to repair 24BF19 (to 73%). Stopped at 60% to repair 22 SGFP. | 1 | 3431 |
| 5/18/20 15:31 | 5/23/20 19:20 | 123.8 | 544 | 67356 | Repair 22 SGFP. Power escalation to 73%. | 1 | 3456 |
| 5/23/20 19:20 | 5/24/20 17:22 | 22.0 | 91 | 2005 | Startup From 2R24 (Continued from 73%) | 1 | 2070 |
| 5/25/20 13:54 | 5/25/20 14:59 | 1.1 | 5 | 5 | 21 Bleed Steam Coil Drn Tank Tuning | 1 | 3502 |
| 5/26/20 3:00 | 5/28/20 16:35 | 61.6 | 10 | 616 | Stopped 23B Circulator Pump for maintenance | 1 | 3273 |
| 5/31/20 23:52 | 6/1/20 0:00 | 0.1 | 31 | 4 | 26B Feedwater Heater Manway Leak | 1 | 3441 |